

Series image - Reference only

EU RoHS	China RoHS	
ELV and RoHS Compliant		

Search Parts in this Series 19164 Series

Application Tooling

Global

DescriptionProduct #Hand Crimp Tool0640016100

Part Number:0191640076

Status: Active

Description:Perma-Seal[™] Female Quick Disconnect Receptacle for 10-12 AWG Wire, Tab Size 6.35mm (.250") x .081mm (.032")

Documents:

Drawing (PDF)

- Product Literature (PDF)
- Related Catalog Page (PDF)

Order Products:

Check Distributor Inventory

T

Part Detail: (show all)

o General

o Physical

o Electrical

o Material Info

General

Quick Disconnects
<u>19164</u>
Perma-Seal™
Quick Disconnect
Closed
94 V0
Female
NiAc(TM)
None
Brass
Straight
Box
0.81mm (.032")
6.35mm (.250")

Orientation	Straight
Packaging Type	Box
Tab Thickness	0.81mm (.032")
Tab Width	6.35mm (.250")
Temperature Range - Operating	-55°C to +125°C
Wire Insulation Diameter	5.84mm (.230") max.
Wire Size AWG	10
Wire Size AWG	12
Wire Size mm ²	4.00 - 6.00


Electrical


CSA	LR18689
UL	E79133
Voltage - Maximum	600V

Material Info


Old Part Number	SC-9281
-----------------	---------

	IO		g)		8	7			6	5		4	3
	MATERIAL NUMBER		NEERING MBER	TAPE MATERIA NUMBEF		TAPE ENGINEERING NUMBER	WIRE SIZE AWG		SIZE SQ.	FITS MALE TAB	PERMA-SEAL COLOR	A MAX.	D MWID	e Min
_	191640017	SAA	4-9261	19164001	18	SAA-926 IT	22-18	.25-	- 1.5	.250 X .032	RED	1.63/41.4	.17/4.3	.083/2.11
F	191640050	SBB	8-9263	19164005	51	SBB-9263T	16-14	_0-	2.5	.250 X .032	BLUE	1.46/37.1	.17/4.3	.083/2.11
	191640076	SC·	-9281	19164030)5	SC-928 IT	2- 0	4.0-	-6.0	.250 X .032	YELLOW	1.52/38.6	.23/5.8	.140/3.56





7



NOTES:

LBORD.DGN REV A 96/06/12 LEVEL 4

Е

D

С

В

А

- I.FEMALE RECEPTACLE CONFORMS TO NEMA.
- 2. ALL DIMENSIONS SHOWN ARE BEFORE Shrink tubing is heated.
- 3. "MWID" DENOTES MAX. WIRE INSULATION DIA.

(C) 4. TAB MATERIAL: .018 THK, BRASS, PLATING, TIN.

8

<u>/5.</u>INSULATION MAT'L: MOLDED NYLON

<u>6</u>NIAC TUBING WITH HOTMELT INNER LINER. SEE CHART FOR COLOR.

9

SALES DRAWING

6		5			4		
	1	draft whe remain			BLE MUST Ensions		DRAWING CON Porated and
WAS Ec NG DRWN CH'K: APPR:	_			R: ± 1/		cad file SD-191	ename 64-020 ₋ C
	=0	I PLACE	±0.2	25	<u>+</u> .	RWD	02/10/
E T C MD 05		2 PLACES	±0.	3	±_O	APPROVE	
20		3 PLACES	±O.		±.005	CHECKED	BY & DATE 02/10/
03-0 03-0 0		4 PLACES	±O.		± .	BRE	02/10/
0 - 0 0 3 3 4 0	MAJOR		m	nm	INCH	DRAWN B	Y & DATE
102 13720 13720	QUALITY SYMBOLS			DLERAN Pecifie		scale NO:NE	DESIGN UNIT
	1						