

308 Constitution Drive Menlo Park, CA 94025-1164 Phone: 800-227-4856 www.circuitprotection.com

PolySwitch® PTC Devices

Overcurrent Protection Device

Raychem Circuit Protection Products

current Protection Device

PRODUCT: AHRF450

DOCUMENT: SCD 25183 PCN: A05383 REV LETTER: C

REV DATE: MAY 8, 2007 PAGE NO.: 1 OF 2

Specification Status: Released

Electrical Rating Voltage: 16V_{DC} MAX

Insulating Material:

Cured, Flame Retardant Epoxy Polymer

Lead Material:

20 AWG Tin Plated Copper (0.8 mm [0.032] nom. diameter)


Part Marking:

Ravchem Logo and Voltage

 \times 16

mm in*:

HF4.5 — Part Identification






TABLE I. INSTALLATION ENVELOPE DIMENSIONS:

	Α		В		С		D		Е		F	G	
	MIN	MAX	MIN	MAX	MIN	MAX	MIN	MAX	MIN	MAX	TYP	MIN	MAX
า:		10.4		15.6	4.3	5.8	7.6	-		3.0	1.2		3.94
:		(0.41)		(0.61)	(0.17)	(0.23)	(0.30)			(0.12)	(0.05)		(0.16)

^{*}Rounded off approximation

TABLE II. PERFORMANCE RATINGS:

CURRENT RATINGS		TIME TO TRIP	RESIS	TANCE	R _{a MAX}	TRIPPED- STATE POWER	
AMPS		SECONDS AT	OHMS		OHMS	DISSIPATION WATTS AT	
AT 2	_	25°C, 22.5 A		25°C	AT 25°C	25°C	
HOLD	TRIP	MAX	MIN	MAX		TYP	
4.5	8.7	4.0	0.017	.036	0.054	3.6	

Reference Documents: PS400, PS300 (reference for R_{1 MAX})

Precedence: This specification takes precedence over documents referenced herein.

Effectivity: Reference documents shall be the issue in effect on the date of invitation for bid.

CAUTION: Operation beyond the rated voltage or current may result in rupture, electrical arcing or flame.

Materials Information

ROHS Compliant ELV Compliant Pb-Free

Directive 2002/95/EC Compliant Directive 2000/53/EC Compliant



© 2005,2007 Tyco Electronics Corporation. All rights reserved



PolySwitch® PTC Devices

Overcurrent Protection Device

DOCUMENT: SCD 25183 PCN: A05383 REV LETTER: C

AHRF450

REV DATE: MAY 8, 2007 PAGE NO.: 2 OF 2

PRODUCT:

308 Constitution Drive Menlo Park, CA 94025-1164 Phone: 800-227-4856 www.circuitprotection.com

Raychem Circuit Protection Products

TABLE III. AUTOMOTIVE SPECIFIC STRESS TESTS AND TEST CONDITIONS:

ELECTRICAL STRESS TESTS	TEST CONDITIONS (see note 2)
ESD Voltage Withstand (see note 1)	25kV
Short Circuit Fault Current Durability	25 cycles, 16V, 200A
Fault Current Durability	350 cycles, 16V/100A
End-of-life Mode Verification	1750 cycles, 16V/100A
Jump Start Endurance (see note 1)	3 cycles, 26V, 1 minute duration
Load Dump Endurance (see note 1)	10 cycles, 86.5V

Note 1: The PolySwitch devices are tested in series with a load resistance and the voltages specified in the test conditions are shared between the PolySwitch device and the load resistance as specified in PS400.

Note 2: Please refer to Appendix A of PS400 for the detailed test procedures